

IF METER AND BOX ARE NOT INSTALLED, COPPER TUBING IS TO BE EXTENDED A MINIMUM OF 24" ABOVE GROUND WITH FEMALE ADAPTER AND A PVC PLUG TO PREVENT DIRT FROM ENTERING CONNECTION.

ACSA RESPONSIBILITY ← | → CUSTOMER RESPONSIBILITY

METER BOX AS SPECIFIED

36" x 30" (INSIDE)

NON-TAPERED WALLS

CAST IRON FRAME & COVER WITH TOUCH READ HOLE AS SPECIFIED

TOP OF BOX LEVEL WITH FINISHED GRADE

FLANGED CONNECTORS  
STRAIGHT COMPRESSION FITTING REQ'D.

IF CUSTOMER IS NOT CONNECTED, COPPER TUBING IS TO BE EXTENDED A MINIMUM OF 24" ABOVE GROUND WITH FEMALE ADAPTER AND A PVC PLUG TO PREVENT DIRT FROM ENTERING CONNECTION.

CORPORATION STOP

SERVICE LINE PER SPECS

SHUT OFF VALVE

METER AS SPECIFIED  
2" CLEAR SPACE BETWEEN BOTTOM METER AND GRAVEL BED

CAP WITH SUITABLE PLUG OR RECONNECT TO EXISTING SERVICE WITH FLEXIBLE COUPLING

METER SETTER WITH BY-PASS, FLANGED VALVE ON INLET AND OUTLET

INSTALL 1" x 15" PIPE FOR STABILITY OF SETTER

BRICKS PLACED RADIALLY (6 MINIMUM)

12" GRAVEL BED UNDER SERVICE LINE BROWN RIVER STONE; PLACE ADDITIONAL STONE INSIDE BOX AS SHOWN

**AUGUSTA COUNTY SERVICE AUTHORITY  
VERONA, VIRGINIA**

SCALE: NONE

DRAWN BY:

DATE: FEB. 1996

REVISED: AUG. 2004

**TYPICAL WATER SERVICE  
CONNECTION 1½" & 2"**

DRAWING NUMBER: W-10

PAGE: 1 OF 1

