



LATERAL DIAMETER, D	ALLOWABLE NUMBER OF CONNECTIONS TO BE SERVED
4"	1
6"	2

**AUGUSTA COUNTY SERVICE AUTHORITY  
VERONA, VIRGINIA**

NOTES:

- TRACER WIRE SHALL BE PLACED FOR EACH CONNECTION AND FOR ANY MAINLINE OR SIDEWALK COLLECTOR THAT DOES NOT TERMINATE WITH A MANHOLE. TRACER WIRE SHALL BE PLACED WITH ACSA INSPECTION OVERSIGHT (PRIOR TO BACKFILL).
- SLOPE NOT LESS THAN 1% UNLESS APPROVED BY ACSA.

SCALE: NTS	DRAWN BY: ACSA
DATE: APRIL 2005	REVISED: APRIL 2021
<b>TYPICAL RESIDENTIAL SERVICE CONNECTION LESS THAN 8' DEEP</b>	
DRAWING NUMBER: S-2A	PAGE: 1 OF 1