



NOTES:

1. FOR PIPES 18" AND SMALLER, SET MECHANICAL PLUG INTO ALL PIPES ENTERING THE MANHOLE.
2. FOR PIPES 18" AND LARGER, PROVIDE A MASONRY PLUG BULKHEAD IN LIEU OF MECHANICAL PLUGS.
3. A WRITTEN SAFETY PLAN MUST BE SUBMITTED FOR REVIEW AT LEAST 48 HOURS PRIOR TO ANY WORK INVOLVING ACSA OWNED STRUCTURES REQUIRING CONFINED SPACE ENTRY AND/OR WORKING AT HEIGHTS.

AUGUSTA COUNTY SERVICE AUTHORITY VERONA, VIRGINIA	
SCALE: NTS	DRAWN BY: ACSA
DATE: FEB. 2021	REVISED:
SANITARY SEWER MANHOLE ABANDONMENT	
DRAWING NUMBER: S-9	PAGE: 1 OF 1