

FISHERSVILLE REGIONAL WWTP LOCAL LIMITS (mg/L)	
Pollutant	Current Limit
BOD	250
Oil and Grease	100
pH (Standard Units)	5.0 – 11.0
TSS	250
Arsenic	0.48
Cadmium	0.12
Chromium	4.84
Copper	4.59
Cyanide	0.48
Lead	0.48
Mercury	0.0016
Nickel	4.85
Silver	1.21
Zinc	0.89

Effective date: 7/13/2020